

7. QUALITY

- 7.1 Specifications. The Gas delivered by either party to the other hereunder shall be of such quality that it shall meet at least the following specifications:
- (a) Be commercially free from objectionable odors, dirt, dust, iron particles, gums, gum-forming constituents, gasoline, PCB's, and other solid and/or liquid matter, including but not limited to water, gas treating chemicals and well completion fluids and debris, which may become separated from the Gas during the transportation or storage thereof.
 - (b) Contain not more than one half (1/2) of one grain of hydrogen sulphide per one hundred (100) cubic feet, as determined by the cadmium sulfate quantitative test, nor more than ten (10) grains of total sulphur per one hundred (100) cubic feet.
 - (c) The Gas delivered hereunder shall not contain more than two-tenths of one percent (0.2%) by volume of oxygen, shall not contain more than two percent (2%) by volume of carbon dioxide, shall not contain more than two and one half percent (2.5%) by volume of nitrogen, and shall not contain a combined total of carbon dioxide and nitrogen components of more than four percent (4%) by volume.
 - (d) Have a heating value of not less than nine hundred and sixty-seven (967) Btu's per cubic feet and not more than one thousand one hundred and ten (1110) Btu's per cubic feet.
 - (e) Have a temperature of not more than one hundred twenty degrees Fahrenheit (120 degrees F), nor less than forty degrees Fahrenheit (40 degrees F).
 - (f) Have been dehydrated by the tendering party, by any method other than the use of a calcium chloride as desiccant, for removal of entrained water in excess of seven (7) pounds of water per million (1,000,000) cubic feet of Gas as determined by dew-point apparatus approved by the Bureau of Mines or such other apparatus as may be mutually agreed upon.
- 7.2 Rejection of Gas. Either party shall be entitled to reject any Gas tendered to it by the other party which does not meet the minimum specifications of Section 7.1 hereunder. Acceptance of such Gas does not constitute any waiver of Steckman Ridge's right to refuse to accept similarly nonconforming Gas.
- 7.3 Waiver of Requirements. Steckman Ridge may waive the requirements set forth in this Section 7 in order to allow Customer to tender or cause to be tendered Gas which does not, when injected into Steckman Ridge's pipeline, meet the quality

specifications set forth in Section 7; provided that acceptance of such Gas shall not adversely affect Steckman Ridge's system facilities or operations, and further provided that once such Gas has been blended, to the extent blending occurs, the commingled Gas stream at any Point of Delivery on Steckman Ridge's system shall be compliant with the quality specifications set forth in Section 7. Steckman Ridge shall post on the LINK® System any waiver of Steckman Ridge's gas quality requirements. Steckman Ridge shall implement this Section 7.3 on a non-discriminatory basis and may cancel any waiver at any time if necessary to assure that the commingled Gas stream is compliant with the quality specifications set forth in Section 7 at any Point of Delivery on Steckman Ridge's system.